



NOTES:

1. CURB STOPS TO BE PLACED 0.30 INSIDE PROPERTY LINE.
2. PRE-INSTALLED SERVICE CONNECTIONS TO BE INSTALLED 6.00 INSIDE PROPERTY LINE WHEN CROSSING GAS AND OTHER SHALLOW UTILITIES.
3. SERVICE VALVES SHALL MAINTAIN A MIN. 3.00 SEPARATION TO THE EDGE OF TRANSFORMERS, JUNCTION TERMINALS OR ANY OTHER SURFACE STRUCTURES.

**TYPICAL ROAD ASSIGNMENTS
RESIDENTIAL 7.00 ROAD**

SCALE _____ N.T.S.

TWIN VALLEY RESORT
7.00 RESIDENTIAL ROAD
CROSS SECTION

LEE MAHER
ENGINEERING ASSOCIATES LTD.